



*DESIGNED FOR QUALITY OR PENALTY?

MDOT 12SP-604B-07 - Non PWL for Air When Pumping

Water Bridge Plaza
Project
2012
Eastman

*Questions

*WHY DO PENALTIES OCCUR?


- * 15 year technician at the plant reporting 6.0% - 7.0% air...

*HOW OFTEN WILL PENALTIES OCCUR?

- * Can penalties be forecasted?

*WHAT CAN BE DONE TO REDUCE PENALTY FREQUENCY?

Water Bridge Plaza
Project
2012
Eastman



* Inherent Variability

* DATA MEASUREMENTS, EVEN WHEN GENERATED UNDER SIMILAR CONDITIONS MAY YIELD DISSIMILAR RESULTS.

* THIS LACK OF PRECISION IS CALLED VARIABILITY.

* INHERENT VARIABILITY IS THE REASON WHY MY VETERAN'S AIR MEASUREMENT MAY BE DISSIMILAR TO OTHERS.

Water Bridge Plaza
Public Project
2012
Jeff Eastman

* Air Meter Inherent Variability

* 12SP-604B-07 ALLOWS FOR VARIABILITY OF $\pm 0.8\%$

* QC TO QA AIR METER CORRELATION RANGE.

* $\pm 0.8\%$ IS PRECISION STATEMENT FROM C-231 FOR TYPE A (ACME) AIR METER.

* PRECISION STATEMENT FOR TYPE B AIR METER HAS NOT YET BEEN RATIFIED BY ACI.

Water Bridge Plaza
 Bridge Project
 2012
 Jeff Eastman

* Air Meter Inherent Variability

* ACI SUBCOMMITTEE C09 - Interlaboratory study to establish precision statements for C231/C231M.

* X2.2 Air content in the range of 3% to 8%--The multilaboratory standard deviation was found to increase with air content as shown in Table A. Therefore, results of two properly conducted tests by different laboratories on the same material are not expected to differ from each other by more than the value shown in the last column of the lower-half of Table A.

Water Bridge Plaza
 Bridge Project
 2012
 Jeff Eastman

TABLE A Indexes of Precision for Air Contents Between 3 % and 8 %^B

Air Content	Standard Deviation ^A , %	Acceptable Difference Between Two Results ^A , %
Single-operator precision:		
3%	0.12	0.33
4%	0.16	0.44
5%	0.19	0.55
6%	0.23	0.66
7%	0.27	0.77
8%	0.31	0.88
Multilaboratory precision:		
3%	0.17	0.49
4%	0.23	0.65
5%	0.29	0.81
6%	0.35	0.98
7%	0.40	1.14
8%	0.46	1.30

^AThese numbers represent the difference limits (d_{2s}) as described in Practice C670

* Pumped Concrete Variability

Sample Locations Investigated:

- 1) End of the chute
- 2) End of the pump – vertical configuration & no flow restrictions
- 3) End of the pump – vertical configuration, 5" to 4" line with "S" bend pipe
- 4) End of the pump – horizontal configuration, 5" to 4" line with "S" bend pipe
- 5) Horizontal configuration, 5" to 4" line with "S" bend pipe – 10 seconds of vibration
- 6) Horizontal configuration, 5" to 4" line with "S" bend pipe – 60 seconds of vibration

Sampling Location	Air Content (%)	Air Loss (%)	Air Loss as % of Chute Value	Paste Content (%)	Specific Surface (mm ⁻¹)	Air Void Content (%)	Spacing Factor (mm)
1 – Chute	7.4	--	--	20.2	23	7.7	0.114
2 – Vertical no restriction	2.4	5	67.6	--	--	--	--
3 – Vertical with restriction	3.8	3.6	48.6	--	--	--	--
4 – Horizontal with restriction	4.7	2.7	36.5	--	--	--	--
5 – Case 4 + 10 sec. vibration	3.6	3.8	51.4	23	27.6	2.7	0.214
6 – Case 4 + 60 sec. vibration	2.1	5.3	71.6	23.1	17.4	2.1	0.38

Best Regards,
Sherry

BUT - AIR LOSS IS NOT THE SAME FROM TEST TO TEST. IT VARIES

SHERRY SULLIVAN M.A.Sc. P.Eng. LEED AP
Director, Transportation & Built Environment

AIR ADJUSTMENT TABLE (ALL POSSIBLE CHANGES TO INITIAL AIR CONTENT ALLOWABLE BY SPEC)

		AIR METER CORRELATION																
		-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
AIR LOSS VIA PUMP	-1.5%	-2.3%	-2.2%	-2.1%	-2.0%	-1.9%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%
	-1.4%	-2.2%	-2.1%	-2.0%	-1.9%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%
	-1.3%	-2.1%	-2.0%	-1.9%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%
	-1.2%	-2.0%	-1.9%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%
	-1.1%	-1.9%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%
	-1.0%	-1.8%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%
	-0.9%	-1.7%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%
	-0.8%	-1.6%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%
	-0.7%	-1.5%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%
	-0.6%	-1.4%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%
	-0.5%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%
	-0.4%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%
	-0.3%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%
	-0.2%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%
	-0.1%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%
	0.0%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

		AIR METER CORRELATION																
		-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
AIR LOSS VIA PUMP	-1.5%	3.2%	3.3%	3.4%	3.5%	3.6%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%
	-1.4%	3.3%	3.4%	3.5%	3.6%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%
	-1.3%	3.4%	3.5%	3.6%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%
	-1.2%	3.5%	3.6%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%
	-1.1%	3.6%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%
	-1.0%	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%
	-0.9%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%
	-0.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%
	-0.7%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%
	-0.6%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%
	-0.5%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%
	-0.4%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%
	-0.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%
	-0.2%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%
	-0.1%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%
	0.0%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%

Total Chances 272
 Passing Chances 45
 Failing Chances 0

Percent Chance of Being in Spec. 16.5%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

6.00%

AIR LOSS VIA PUMP	AIR METER CORRELATION																
	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
	3.7%	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%
	3.8%	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%
	3.9%	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%
	4.0%	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%
	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%
	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%
	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%
	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%
	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%
	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%
	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%
	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%
	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%
	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%
	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%
	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%

Total Chances 272
 Passing Chances 105
 Passing Chances 0

Percent Chance of Being in Spec. 38.6%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

6.40%

AIR LOSS VIA PUMP	AIR METER CORRELATION																
	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
	4.1%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%
	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%
	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%
	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%
	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%
	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%
	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%
	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%
	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%
	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%
	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%
	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%
	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%
	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%
	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%
	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%

Total Chances 272
 Passing Chances 167
 Passing Chances 0

Percent Chance of Being in Spec. 61.4%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

7.10%

AIR METER CORRELATION

	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
-1.5%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%
-1.4%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%
-1.3%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%
-1.2%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%
-1.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%
-1.0%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%
-0.9%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%
-0.8%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%
-0.7%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%
-0.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%
-0.5%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%
-0.4%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%
-0.3%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%
-0.2%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%
-0.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%
0.0%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%

Total Chances 272
 Passing Chances 244
 Passing Chances 0

Percent Chance of Being in Spec. 89.7%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

7.50%

AIR METER CORRELATION

	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
-1.5%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%
-1.4%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%
-1.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%
-1.2%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%
-1.1%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%
-1.0%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%
-0.9%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%
-0.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%
-0.7%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%
-0.6%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%
-0.5%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%
-0.4%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%
-0.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%
-0.2%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%
-0.1%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%
0.0%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%

Total Chances 272
 Passing Chances 266
 Passing Chances 6

Percent Chance of Being in Spec. 95.6%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...

7.80%

AIR METER CORRELATION

	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
-1.5%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%
-1.4%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%
-1.3%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%
-1.2%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%
-1.1%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%
-1.0%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%
-0.9%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%
-0.8%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%
-0.7%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%
-0.6%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%
-0.5%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%
-0.4%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%
-0.3%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%
-0.2%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%
-0.1%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%
0.0%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%	8.6%

Total Chances 272
 Passing Chances 272
 Passing Chances 21

Percent Chance of Being in Spec. 92.3%

CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...


8.00%

AIR METER CORRELATION

	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
-1.5%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%
-1.4%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%
-1.3%	5.9%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%
-1.2%	6.0%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%
-1.1%	6.1%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%
-1.0%	6.2%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%
-0.9%	6.3%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%
-0.8%	6.4%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%
-0.7%	6.5%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%
-0.6%	6.6%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%
-0.5%	6.7%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%
-0.4%	6.8%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%
-0.3%	6.9%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%
-0.2%	7.0%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%	8.6%
-0.1%	7.1%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%	8.6%	8.7%
0.0%	7.2%	7.3%	7.4%	7.5%	7.6%	7.7%	7.8%	7.9%	8.0%	8.1%	8.2%	8.3%	8.4%	8.5%	8.6%	8.7%	8.8%

Total Chances 272
 Passing Chances 272
 Passing Chances 36

Percent Chance of Being in Spec. 86.8%



*Statistician Vetting

*Estimate the likelihood of meeting 5.5% - 8.0% air content at POP when pumped per 12SP-604B-07.


*Givens:

- * The measured/tested air content before the pump is 5.5% to 8.0%.
 - * Air is normally distributed with a mean of 6.75% and standard deviation of 0.625%. This equates to air content of 5.5% - 8.0% 95% of the time.
 - * Air loss due to pumping may be between 0.0% to -1.5%.
 - * Loss is normally distributed with a mean of 0.75% and standard deviation of 0.375%. This equates to air loss between 0% - (-1.5%) 95% of the time.
 - * Difference between QA and QC air meters may be -0.8% to +0.8%.
 - * Difference is normally distributed with a mean of 0% and standard deviation of 0.4%. This equates to difference between -0.8% and +0.8% 95% of the time.
- Water Bridge Plaza
Pump Project
2013-2014
JEP Eastman

- * A Monte Carlo (computer) simulation was performed to estimate the likelihood of having the QA air content OUT OF SPECIFICATION per previous three variables/givens.
- * The simulated process output is the variable of interest and defined as:
 - * $\text{QA measured air} = (\text{QC air content}) - (\text{pump air loss}) + (\text{difference between meters})$
- * An expected value analysis (EVA) based on 1,000,000 simulated values was used to estimate the likelihood of having concrete results at the job site fall inside and outside 5.5% to 8.0%.


Water Bridge Plaza
 Project
 2012
 Eastman

QA Measured Air




- * Results of EVA show a high percentage of QA measurements that would be expected to fail Mdot air specification.

Water Bridge Plaza
 Project
 2012
 Eastman



*Optimum Target Air

- *Increasing the target air content (before pumping & correlation) from 6.75% to 7.5% (~ +1.0 sigma) would reduce the likelihood of out of spec concrete to **14%**.
- *14% implies that one out of every six trucks would still fall outside the limits set by Mdot, even if the producer is making within spec concrete before pump/correlation.



AIR ADJUSTMENT TABLE
ALL POSSIBLE CHANGES TO INITIAL AIR CONTENT ALLOWABLE BY
CHANGED SPEC - 0.5% PUMP AIR LOSS & +/-0.8% METER VARIABILITY

		AIR METER CORRELATION																
		-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
AIR LOSS VIA PUMP	-0.5%	-1.3%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%
	-0.4%	-1.2%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%
	-0.3%	-1.1%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%
	-0.2%	-1.0%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%
	-0.1%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%
	0.0%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%

Water Bridge Plaza
 Bridge Project
 2/28/2012
 Jeff Eastman



CHANCES OF BEING IN SPEC WHEN MIXER AIR IS...



5.50%		AIR METER CORRELATION																
		-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	0.5%	0.6%	0.7%	0.8%
AIR LOSS VIA PUMP	-0.5%	4.2%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%
	-0.4%	4.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%
	-0.3%	4.4%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%
	-0.2%	4.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%
	-0.1%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%
	0.0%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	6.0%	6.1%	6.2%	6.3%



Total Chances 102
 Passing Chances 39
 Failing Chances 0

Percent Chance of Being in Spec. 38.2%

Water Bridge Plaza
 Bridge Project
 2/28/2012
 Jeff Eastman







AIR ADJUSTMENT TABLE
ALL POSSIBLE CHANGES TO INITIAL AIR CONTENT ALLOWABLE BY
CHANGED SPEC - 0.5% PUMP AIR LOSS & +/-0.4% METER VARIABILITY

		AIR METER CORRELATION									
		-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	
AIR LOSS VIA PUMP	-0.5%	-0.9%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	
	-0.4%	-0.8%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	
	-0.3%	-0.7%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	
	-0.2%	-0.6%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	
	-0.1%	-0.5%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	
	0.0%	-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	



Water Bridge Plaza
 Phase Project
 2/28/2012
 Jeff Eastman



		AIR METER CORRELATION									
		-0.4%	-0.3%	-0.2%	-0.1%	0.0%	0.1%	0.2%	0.3%	0.4%	
AIR LOSS VIA PUMP	-0.5%	4.6%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	
	-0.4%	4.7%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	
	-0.3%	4.8%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	
	-0.2%	4.9%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	
	0.1%	5.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	
	0.0%	5.1%	5.2%	5.3%	5.4%	5.5%	5.6%	5.7%	5.8%	5.9%	



Total Chances 54
 Passing Chances 15
 Failing Chances 0

Percent Chance of Being in Spec. 27.8%

Water Bridge Plaza
 Phase Project
 2/28/2012
 Jeff Eastman







* Conclusion

- * Inherent variability between air meters and pumped concrete will result in penalties.
 - * **ITS IS NOT POSSIBLE TO REDUCE AIR METER PRECISION FROM 1.3% TO 0.4%!**
 - * **PUMPED CONCRETE INHERENT VARIABILITY OF -1.5% IS A REASONABLE ASSUMPTION.**
- * At optimum initial air content, one out of six trucks will contain an out of spec air content (14%).
- * Per ACI-329, this inherent variability must be accounted for in the interest of fairness, **BECAUSE IT CAN NOT BE MITIGATED.**

Water Bridge Plaza
East Project
2012
Eastman